

June 8,
2010



Cooling Tower Cleaning/ Dewatering

Dewatering Units – Vacuum Box with Filter Basket

- FLOOR: 1/4" PL one piece
- CROSSMEMBER: 3 x 4.1 channel 12" on center
- WALLS/ROOF: 1/4" PL solid welded, inside liner hooks
- STRUCTURE: Tubing and formed channel supports rated to operated at 30" hg
- DOOR: 1/4" PL with tubing frame
- FRONT: 1/4" PL with push plates
- PICK UP: Standard cable with 2" x 6" x 1/4" rails, gusset at each crossmember
- WHEELS: (4) 10" DIA x 9" long with grease fittings
- DOOR LATCH: (4) independent ratchet binders with chains, vertical second latch
- GASKETS: Extruded rubber seal with metal retainers
- WELDS: All welds continuous except sub structure crossmembers
- FINISH: Coated inside and out with direct to metal, rust inhibiting acrylic enamel color coat
- HYDROTESTING: Full capacity static test
- DIMENSIONS: 22'-11" long (21'-8" inside), 94" wide (83" inside)

